

BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

BACnet Testing Laboratories Product Listing

This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the manufacturer's PICS statement on the BI website.

Listing Information (BTL-30129)

Vendor		Listing Status
Carel S.p.A. Via dell'Industria 11 35020 Brugine (PD) Italy		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of November 2014	Revision 14 (135-2012)	March 2017

Product Name	Model Numbers	Software Version
	P+5 XX ¹ X ² X ³ X ⁴ X ⁵ X ⁶ X ⁷ X ⁸ X ⁹	
c.pCO Family	where XX^1 is 00, 04, 0N, K0, HV, PX or DN X^2 is S X^3 is B, E, F, G, N or W X^4 is 0, A, B, C, D, E, F, G, H, Z, 7, 8 or 9 X^5 is 0, 1, 2, 3, 4, 5, 6, A, B, C, D, E, F or Z X^6 is 0, 1, 2, 3, 4, 5, 6, 7 or 8 X^7 is 0 or E X^8 is X, S, M, L, C or Z X^9 is 0, 1, 2 or K	FW: v4.1.005r6183, AW: 1.00.039
c.pCO Family	$\begin{array}{c} \textbf{P+D} XX^{1} X^{2} X^{3} X^{4} X^{5} \\ \textbf{X}^{6} \textbf{X}^{7} \textbf{X}^{8} \textbf{X}^{9}, \\ \textbf{P+P} XX^{1} X^{2} X^{3} X^{4} X^{5} \\ \textbf{X}^{6} \textbf{X}^{7} \textbf{X}^{8} \textbf{X}^{9}, \\ \textbf{P+R} XX^{1} X^{2} X^{3} X^{4} X^{5} \\ \textbf{X}^{6} \textbf{X}^{7} \textbf{X}^{8} \textbf{X}^{9} \\ \textbf{Where} \\ \textbf{X}^{1} \text{ is } 00, 0N, 0R, 0B, HV \text{ or} \\ \textbf{NM} \\ \textbf{X}^{2} \text{ is } 0 \\ \textbf{X}^{3} \text{ is } U, N, B \text{ or } \textbf{F} \\ \textbf{X}^{4} \text{ is } 0, C, B, E \text{ or } \textbf{H} \\ \textbf{X}^{5} \text{ is } 0, 1, A, B, C \text{ or } \textbf{D} \\ \textbf{X}^{7} \text{ is } 0, \textbf{N} \text{ or } \textbf{F} \\ \textbf{X}^{8} \text{ is } 0, \textbf{N} \text{ or } \textbf{F} \\ \textbf{X}^{8} \text{ is } 0, \textbf{N} \text{ or } \textbf{F} \\ \textbf{X}^{9} \text{ is } 0, \textbf{1} \text{ or } \textbf{K} \end{array}$	FW: v4.1.005r6183, AW: 1.00.039

Device Profiles

Profile	Model Numbers
BACnet Building Controller (B-BC)	All models

BIBBs Supported

	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
Data Sharing	WriteProperty-B	DS-WP-B
-	WritePropertyMultiple-A	DS-WPM-A
	WritePropertyMultiple-B	DS-WPM-B
	COV-A	DS-COV-A
	COV-B	DS-COV-B
	COV-Unsubscribed-B	DS-COVU-B

	Notification Internal-B	AE-N-I-B
Alarm and Event Notification	ACK-B	AE-ACK-B
	Alarm Summary-B	AE-ASUM-B
	Enrollment Summary-B	AE-ESUM-B
	Information-B	AE-INFO-B

Scheduling Internal-B External-B	SCHED-I-B

Tranding	Viewing and Modifying Trends Internal-B	T-VMT-I-B
Irending	Automated Trend Retrieval-B	T-ATR-B

	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
Device Management	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-B	DM-BR-B
	Restart-B	DM-R-B

Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Calendar	Device	File
Integer Value	Multi-State Input	Multi-State Output
Multi-State Value	Notification Class	Positive Integer Value
Schedule	Trend Log	

Data Link Layer Options

Media	Options
BACnet/IP (Annex J)	Register as Foreign Device
MS/TP Master	

Character Set Support

ISO 10646 (UTF-8)	
-------------------	--