

FCU SOFTWARE BUNDLE 2.2.3 25.06.2020

The list below contains modifications and new features since the release of software bundle 2.2.2.

<p>Software bundle</p> <p>ver. 2.2.3</p>	<p>Improvements:</p> <ul style="list-style-type: none"> • Added new FCU Updater v2.2.0 to the bundle
--	--

FCU SOFTWARE BUNDLE 2.2.2 27.01.2020

The list below contains modifications and new features since the release of software bundle 2.2.0.

<p>Firmware</p> <p>ver. 2.1</p> <p>Release date 27.01.2020</p>	<p>Improvements:</p> <ul style="list-style-type: none"> • Added possibility to invoke actions CopyFromDefaultToNV and CopyFromNVToDefault remotely <p>Fixed bugs:</p> <ul style="list-style-type: none"> • SlaveNetwork BACnet DeviceName slot is updated by the change of the BACnet Object Name property. • NV components are getting status Fault when trying to add the component if the application already have limited quantity of components (slot Free NV Boolean/Numeric in plat service) • NVNetNumeric and NVNetBoolean components facet MAX for slots Analog/Binary Value Id updated for proper number (230/240 instead of 200)
<p>Kits for firmware</p> <p>ver. 2.1</p> <p>Release date 27.01.2020</p>	<p>Improvements:</p> <ul style="list-style-type: none"> • Added new kit iSMA Building with Sunblind and AdvanceSunblind components <p>Fixed bugs:</p> <ul style="list-style-type: none"> • iSMA-FCU kit FanControl component fixed for restarting fan work after getting signal about closed windows and changing FanMode setting at the same time.

FCU SOFTWARE BUNDLE 2.2.0

25.09.2018

The list below contains modifications and new features since the release of software bundle 2.1.0.

<p>Firmware</p> <p>ver. 2.0</p> <p>Release date 25.05.2018</p>	<p>Improvements:</p> <ul style="list-style-type: none"> • BACnet BTL compatible firmware <p>Fixed bugs:</p> <ul style="list-style-type: none"> • Fixed stopping communication if a Slave Device answers with a Service Error Telegram • List of BACnet services in Device Object updated according to BTL requirements • Fixed lifetime out of range detection in COV subscription • Fixed database revision incrementation after any BACnet ID change • Fixed Device Objects properties for compability with BTL requirements
<p>Kits for firmware</p> <p>ver. 2.0</p> <p>Release date 25.09.2018</p>	<p>Fixed bugs:</p> <ul style="list-style-type: none"> • Fixed components in kit iSMA_RoomDevices_Modbus such as SubmenuNumeric, SubmenuBoolean, MainMenuNumeric, MainMenuBoolean • Fixed FanControl and PWM components in kit iSMA_FCU • Fixed components in kit iSMA_RoomDevices_Modbus related to the problem when connecting the LP Panel

FCU SOFTWARE BUNDLE 2.1.0

13.03.2018

The list below contains modifications and new features since the release of software bundle 2.0.0.

<p>Firmware</p> <p>ver. 1.4</p> <p>Release date 13.03.2018</p>	<p>New functions:</p> <ul style="list-style-type: none"> • Added SVM state (with error codes) available on Modbus register 99 and on BACnet in object Device, as property 5002 <p>Improvements:</p> <ul style="list-style-type: none"> • Immediate getting and displaying new values in NVNet components after calling “Copy from Default to NV” and “Copy from User to NV” • Printing console messages improved <p>Fixed bugs:</p> <ul style="list-style-type: none"> • Starting big applications, which failed during update from FW1.1 to FW1.3 • Writing NV values to EEPROM • Upgrade of FW for new hardware • Default setting doesn't cause wrong 0 values on Modbus • Crashing the application during updating procedure for multiple devices • FCU PID component behaviour after restarting SVM • FCU PID and PI components calculating start value • FCU PID component out value while slot is “Disabled”
<p>Default application</p> <p>ver. 2.2</p> <p>Release date 13.03.2018</p>	<p>New functions:</p> <ul style="list-style-type: none"> • Added network variable Valves_dead_band (BACnet AV:39; Modbus 139) • Dead band for PI Control Implemented in default application <p>Improvements:</p> <ul style="list-style-type: none"> • Application sets for slaves in BACnetMasterSlave Network value of FCU_Mode as Heating_only or Cooling_only related to Master's present value of Heating/Cooling mode.

FCU SOFTWARE BUNDLE 2.0.0

14.09.2017

The list below contains modifications and new features since the release of software bundle 1.1.0.

Name	Description
<p>Default application ver. 2.0</p> <p>Release date 14.09.2017</p>	<p>Improvements:</p> <ul style="list-style-type: none"> • Switching of temperature sensor logic improved • Optimized logic of iSMA-B-LP Room Panel operation • Added network variable for BACnetMasterSlave network ping frequency <p>Fixed bugs:</p> <p>Fan control according to FCU Mode bug fixed</p>
<p>Firmware ver. 1.3</p> <p>Release date 14.09.2017</p>	<p>New functions:</p> <ul style="list-style-type: none"> • Created new kit iSMA_Advanced with components: <ul style="list-style-type: none"> ▪ RaiseLower for actuator open/close control signals ▪ Dimmer Switch for single or double switch dimming control ▪ Action Trigger for remote calling action of any component in application • Added new kit iSMA_RoomDevices_Modbus with several components for iSMA-B-LP Room Panel operation optimization <p>Improvements:</p> <ul style="list-style-type: none"> • Improved stability and functionality of FCU_FanControl component • Improved switching Return and Space Sensors in FCU_Temperature_Sensor_Switch • Limiting of values from forbidden ranges in several components of various kits • Slaves addresses range expanded by Local Remote Auto Binding mode in FCU_MasterSlave component <p>Fixed bugs:</p> <ul style="list-style-type: none"> • Default Settings called remotely (e.g by FCU_Updater) • FCU_EffectiveSetpointCalculator component for Standby Offset • FCU_OutputSwitch component for Second Stage control • NaN value in NVNetNumeric and NVnetBoolean components

FCU SOFTWARE BUNDLE 1.1.0 09.02.2017

The list below contains modifications and new features since the release of software bundle 1.0.0.

Name	Description
<p>Default application ver. 1.6</p> <p>Release date 09.02.2017</p>	<p>New functions:</p> <ul style="list-style-type: none">• Added ability of manual control of the outputs from a remote system (BMS)• Added ability of monitoring of the control signal values and the outputs' states in the iSMA-B-LP• Added new network variables in order to extend the possibility of the iSMA-B-LP configuration from a remote system (BMS) <p>Improvements:</p> <ul style="list-style-type: none">• Functions and components implemented in default application improvements <p>Fixed bugs:</p> <ul style="list-style-type: none">• Analog Outputs links• Anti-frost function for binary control• Test mode function for binary control

FCU SOFTWARE BUNDLE 1.0.0 06.12.2016

Name	Description
Software Bundle 1.0.0 Release date 06.12.2016	<ul style="list-style-type: none">• First release