



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

BACnet Testing Laboratories Product Listing

This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the manufacturer's PICS statement on the BI website.

Listing Information (BTL-30200)

Vendor		Listing Status
Global Control 5 Sp. z o.o ul. Wyczółki 71 02-820, Warsaw Poland		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of November 2014	Revision 14 (135-2012)	September 2017

Product Name	Model Numbers	Software Version
MIX-Series	iSMA-B-MIX18; iSMA-B-MIX38, iSMA-B-MIX18-IP; iSMA-B-MIX38-IP	6.0

Device Profiles

Profile	Model Numbers
BACnet Smart Sensor (B-SS) BACnet Smart Actuator (B-SA)	All models

BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B
	COV-B	DS-COV-B

Device Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B

Object Type Support

Accumulator	Analog Input	Analog Output
Analog Value	Binary Input	Binary Output
Binary Value	Device	Multi-State Value

Data Link Layer Options

Media	Options
BACnet/IP (Annex J)	Register as Foreign Device
MS/TP Master and Slave	4800, 9600, 19200, 38400, 57600, 76800, 115200

Character Set Support

ISO 10646 (UTF-8)
